

Building Foundation Wall Checklist

For Raised Slab Foundations and Raised Floor System Foundations

Street Address _____ Permit # _____

- Anchor Bolts – Reinforced Cells Grouted –
R4504.2.1
- Sill Plates – 2 Sill Plates Required –
R4504.2.1.2
- Wood Framing in contact w/ masonry or concrete must be preservative Treated.
R317.1
- Foundation Wall Heights exceeding 6’ - 8” with 4’ unbalanced backfill require reinforcing –
R404.1.1
- Crawlspace Ventilation located within 3’ of corners -
R408
- Piers supporting Beams or Girders must be solid filled -
R606.7
- Piers unsupported height not exceeding 10 times least dimension -
R606.7
- Fire Resistant Construction – If <3’ from property line
R302
- Access Panel Door -
R408.8
-

NOTES:

- Passed
- Partial Pass
- Reinspection Required
- Reinspection Required (With Fee)